



Finance and Administrative Services Department · Purchasing Division  
500 Castro Street · Post Office Box 7540 · Mountain View, California 94039-7540 · 650-903-6324 · FAX 650-968-5472

June 3, 2010


RE: PROPOSAL NO. R101771 FENCE AT MOFFETT GATEWAY SITE

ADDENDUM NUMBER ONE

1. Clarification – Lot 1 New Fencing, Item 1, pg 11 – Install corner post adjacent to the corner brick column post on the PG&E property. Extend new fence in a straight line to the corner post of the first 20' wide double gate. From the opposite side corner post of the double wide gate, install new fencing to jog along the curved edge of the access road and continue approx 2' offset along the right edge of the access road all the way to the second double gate, and then beyond the double gate to end run at the existing gate at the Highway 101 access point.
2. Clarification – Item 4, pg 11 Double Gates: Each gate shall be 20' wide – with two each 10' x 6' sections with center opening.
3. Change Section III - Lot No. 2 Repair of Existing Fence, as follows: "The existing chain link fence will be removed and posts shall be cut from their concrete footings at grade level by others. Install approx 1,450 l.f. of new 6' chain link fence and footings along the identical line as the removed fence, per the same fence specifications as Lot 1 New Fencing."

This addendum must be signed below acknowledging receipt and returned with the completed proposal.

Sincerely,



Chris Hartje,  
Supervising Buyer

\_\_\_\_\_  
Signature of Officer  
signifying receipt and understanding of  
this addendum

\_\_\_\_\_  
Date